



1. Select required resistance on R scale
2. Select the calculated soil resistivity on P scale
3. Lay straightedge on R and P scale values and allow it to intersect with the K scale
4. Mark K scale intersection point
5. Lay straightedge on K scale point and DIA scale, and allow to intersect with D scale
6. Point on D scale will be the rod depth required for resistance on R scale